

Certificate

Registration No.: PV 50164563

Page 2

Report No.: 12606253 005

License Holder:

NexPower Technology Corp.

No. 2, Houke S. Rd.,
Houli Township, Taichung County 421,
Taiwan, R.O.C.

Product:

PV Module

Addition

Type: NT-125AX, NT-130AX, NT-135AX,
NT-140AX, NT-145AX

Manufacturing Plant:

NexPower Technology Corp.

No. 2, Houke S. Rd.,
Houli Township, Taichung County 421,
Taiwan, R.O.C.

Basis:

IEC 61646:2008
EN 61646:2008
"Thin-film terrestrial photovoltaic (PV)
modules - Design qualification and type
approval"

Factory Inspection
To document the consistent quality of
the product factory inspections are
performed periodically.



- **Periodic inspection**
- **Qualified, IEC 61646**
- **Safety tested, IEC 61730**

Remarks:

- Additional type designations see above.
- The details of the factory inspection are documented in report no. 12606213.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid for 5 years from the date of issue stated on page 1.



Certification body



Dipl.-Ing. W. Herlitschke

Yokohama, 09 September 2010

TÜV Rheinland Japan Ltd. – Yokohama 222-0033, Japan

Certificate

Registration No.: PV 50164564

Page 2

Report No.: 12606253 006

License Holder:

NexPower Technology Corp.
No. 2, Houke S. Rd.,
Houli Township, Taichung County 421,
Taiwan, R.O.C.

Product:

PV Module

Addition

Type: NT-125AX, NT-130AX, NT-135AX,
NT-140AX, NT-145AX

Manufacturing Plant:

NexPower Technology Corp.
No. 2, Houke S. Rd.,
Houli Township, Taichung County 421,
Taiwan, R.O.C.

Basis:

- IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety
qualification"



- Periodic inspection
- Qualified, IEC 61646
- Safety tested, IEC
61730

- Factory Inspection**
To document the consistent quality of
the product factory inspections are
performed periodically.

Remarks:

- Additional type designations see above.
- Change of maximum system voltage (Voc at STC).
- The fire test (IEC 61730-2 / MST 23) was performed including the type designation on the preceding certificate page.
- The details of the factory inspection are documented in report no. 12606213.
- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants
at a maximum system voltage (Voc at STC) of up to 1000 VDC.


Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or
processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid for 5 years from the date of issue stated on page 1.



Certification body



Dipl.-Ing. W. Herlitschke

Yokohama, 09 September 2010

TÜV Rheinland Japan Ltd. – Yokohama 222-0033, Japan