

Certificate

Registration No.: PV 60025583

Page 1

Report No.: 15032227.001

License Holder:
YINGLI ENERGY (CHINA) COMPANY LIMITED
No. 3399 Chaoyang North Road
Baoding 071000, Hebei
China

Manufacturing Plant:
YINGLI ENERGY (CHINA) COMPANY LIMITED
No. 3399 Chaoyang North Road
Baoding 071000, Hebei
China

Product:
PV Module
Type:
YLxxxP-23b
(xxx = power range 150 – 185 W in increments of 5)
YLxxxP-23b/2
(xxx = power range 150 – 185 W in increments of 5)
YLxxxP-26b
(xxx = power range 180 – 215 W in increments of 5)
YLxxxP-29b
(xxx = power range 200 – 240 W in increments of 5)
YLxxxP-29b/2
(xxx = power range 200 – 240 W in increments of 5)
YLxxxP-32b
(xxx = power range 220 – 265 W in increments of 5)
YLxxxP-35b
(xxx = power range 235 – 285 W in increments of 5)

Basis:

IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

Factory Inspection
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to 1000 VDC.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 15031411.001.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 05 May 2014.



Cologne, 09 June 2009

Dipl.-Ing. M. Adrian